



My Speed Post

भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

S Bhaduri
Executive Director Engg. (Offg.)

D.O. No. AAI/CAP/EDE/MP-TB/2009-10/13351

11th Sept., 2009

Dear Shri Adhikari,

The RCC work in the Domestic Terminal is progressing and likely to be completed by end of January, 2010. It is also not out of place to mention that with all your co-operation and co-ordination, the work is progressing faster. I like to invite your attention to RFI 108 raised in Domestic Terminal, wherein the clearance between the ramp and the soffit of the beam given as 2712 mm, whereas the normal ambulance requires 3200 mm clearance in case of evacuation of the injured people from the basement. You are requested to look into the matter and do the needful to increase the clearance.

Yours sincerely,

S Bhaduri
(S Bhaduri)

Shri Adhikari,
Structural Consultant,
Creative Group,
M-59, Saket,
New Delhi - 110 047.
Fax No. 011 - 2954 3002

Phone: 2256 0541, 2256 0634, 2256 0535, 2256 0536, 2256 0637
Fax : GM-Engg. - 044-2256 0531, Civil - 2256 0027,
Electrical - 2256 043B, F&A/Electronics - 2256 1335

चेन्नाई एयरपोर्ट परियोजना
चेन्नाई - ६०० ०२७.
Chennai Airport Project
Chennai - 600 027.